



Not One Iota Ltd t/a Iota  
10 Tandragee Road,  
Co. Armagh  
N.Ireland  
BT62 3BQ

## WATER ANALYSIS CERTIFICATE



8998

Client Details			
<b>Client:</b>	Hydro-Ease	<b>Arrival Date/Time:</b>	16/03/2023 / 11:00
<b>Client Address:</b>	Unit C3 Inspire Business Park, Carrowreagh Rd, Dundonald, Belfast BT16 1QT		

Project/Site Details			
<b>Site Address:</b>	Hydro-Ease - Unit C3 Inspire Business Park Dundonald		
<b>Sampled By:</b>	D. Barton	<b>Sampling Date/Time:</b>	16/03/2023 / 09:40

Report Details		
<b>Report Number:</b>	23/1269-2	<b>Signature:</b>  D. Bell
<b>Client Ref:</b>	N/A	
<b>Analysis Date/Time:</b>	16/03/2023 / 11:30	
<b>Report Date:</b>	20/03/2023	
<b>Re-Issue Date:</b>	05/05/2023	
<b>Approved By:</b>	Daryl Bell	
<b>Job Title:</b>	Senior Analyst (Water)	

Lab No	Sample Description	SOP	Analysis	Results
21042	1 – Pink Pool	03	TVC 37°C (24hr)	0 cfu/ml
		04	Coliform E.coli	0 cfu/100ml 0 cfu/100ml
		05	Pseudomonas aeruginosa	0 cfu/100ml

**Abbreviations:**

- TNTC – Too Numerous To Count (>2400 cfu/ml)
- CFU – Colony Forming Units
- SOP – Standard Operating Procedure

**Disclaimer:**

- The results relate only to samples tested.
- This Certificate should not be reproduced except in full and with approval of the Laboratory

**Amendments:**

- Sample 21042 only