



Not One Iota Ltd t/a Iota
10 Tandragee Road,
Co. Armagh
N.Ireland
BT62 3BQ

WATER ANALYSIS CERTIFICATE



8998

Client Details			
Client:	Hydro-Ease	Arrival Date/Time:	04/06/2024 / 14:30
Client Address:	Unit C3 Inspire Business Park, Carrowreagh Rd, Dundonald, Belfast BT16 1QT		

Project/Site Details			
Site Address:	Hydro-Ease - Unit C3 Inspire Business Park Dundonald BT16 1QT		
Sampled By:	Ryan Hanlon	Sampling Date/Time:	04/06/2024 / 12:51

Report Details		
Report Number:	24/1734-1	Signature:
Client Ref:	J040308	D. Bell
Analysis Date/Time:	04/06/2024 / 15:20	
Report Date:	06/06/2024	
Approved By:	Daryl Bell	
Job Title:	Senior Analyst (Water)	

Lab No	Sample Description	SOP	Analysis	Results
37427	EH728 – Suite 1 - TAP 1 – Mixed	03	TVC 37°C (24hr)	0 cfu/ml
		04	Coliform E.coli	0 cfu/100ml 0 cfu/100ml
		05	Pseudomonas aeruginosa	0 cfu/100ml
37428	EH729 – Suite 2 - TAP 2 – Mixed	03	TVC 37°C (24hr)	0 cfu/ml
		04	Coliform E.coli	0 cfu/100ml 0 cfu/100ml
		05	Pseudomonas aeruginosa	0 cfu/100ml

Abbreviations:

- TNTC – Too Numerous To Count (>2400 cfu/ml)
- CFU – Colony Forming Units
- SOP – Standard Operating Procedure

Disclaimer:

- The results relate only to samples tested.
- This Certificate should not be reproduced except in full and with approval of the Laboratory